



# ADDENDUM #1

October 15, 2020

**Request for Proposals:** Building Envelope Services

**Project:** Sunshine Coast Community Services Society

**Location:** 5638 Inlet Avenue, Sechelt, B.C.

Question	Answer
1. Should we add Air Barrier Commissioning to our proposal?	Yes. Please add this into your proposal as an <b>optional additional</b> service. This would include: air barrier design, test plans, whole building airtightness and suite level air tests.